

Emil A. Peters GmbH & Co. KG
Connection systems for explosion-risk control

Attestation of Conformity No. 1067-98-09

in compliance with Directive 2014/34/EU - Revision 9

Manufacturer	Emil A. Peters GmbH & Co. KG Connection systems for explosion risk control Westfalenstr. 85 58636 Iserlohn www.emil-a-peters.de
Product	Explosion-protected component bushing Type GD-Series: GD 16/6600, GD16/8800, GD 16/11000 GD 20/6600, GD20/8800, GD 20/11000
Certificate No	PTB 98 ATEX 1067 U IECEX PTB 08.0054U
Inspection body	PTB Physikalisch-Technische Bundesanstalt Zertifizierungsstelle Explosionsschutz Bundesallee 100 38116 Braunschweig

The product as set out above is in conformity with the following standards:

EN IEC 60079-0:2018/AC:2020 resp. IEC 60079-0:2017 (Ed.7.0)

EN 60079-1:2014/AC:2018 resp. IEC 60079-1:2014/ (Ed. 7.0)

EN IEC 60079-7:2015/A1:2018 resp. IEC 60079-7: 2017 (Ed.5.1)


as well as the relevant standards.

This is to confirm conformity of the above-specified Ex-type device: GD-Series bushing conforming with Directive 2014/34/EU and the above standards.

The manufacturer has set up a certified "Production" quality system **PTB 98 ATEX Q006**, which is audited in regular technical audits.

All relevant documents are filed on our homepage in the pdf format.

Iserlohn, dated 13.04.2023


Michael Flamme
Technical Director/Representative for Ex-Devices